

# Water Quality Association

11/17/2014



## CERTIFIED DRINKING WATER TREATMENT UNITS

*NSF/ANSI 42 (02/29/2012): Drinking Water Treatment Units, Aesthetic Effects is within WQA's ANSI and SCC approved scope of accreditation under the Drinking Water Treatment Units Scheme*

### Kinetico Incorporated

10845 Kinsman Road

Newbury, OH 44065

United States

<http://www.kinetico.com> (<http://www.kinetico.com>)

### Product Type: Point-of-Use

Brand Name	Model Number	Flow Rate (GPM)	Replacement Component	Replacement Component Service Cycle (Gallons)	Reduction Claims
AquaKinetic	A-200	1	9306B	500	Aesthetic Chlorine, Taste and Odor
Kinetico	Drinking Water Filter Model 7000	1.0	9306B	500	Aesthetic Chlorine, Taste and Odor
Kinetico	Drinking Water Filter Model 7500	0.75	9308A	500	Aesthetic Chlorine, Taste and Odor
Kinetico	K5 Drinking Water Station <sup>1</sup>	1	9306B	500	Aesthetic Chlorine, Taste and Odor
Kinetico	KUBE14	1.25	KUBE14F1	1665	Aesthetic Chlorine, Nominal

# Water Quality Association

11/17/2014



## CERTIFIED HOUSEHOLD AND COMMERCIAL CATION EXCHANGE WATER SOFTENERS

*NSF/ANSI 44 (06/11/2013): Residential Cation Exchange Water Softeners is within WQA's ANSI and SCC approved scope of accreditation under the Drinking Water Treatment Units Scheme*

Kinetico Incorporated

10845 Kinsman Road

Newbury, OH 44065

United States

<http://www.kinetico.com> (<http://www.kinetico.com>)

### Product Type: DIR-Efficiency Rated

Brand Name	Model Number	Flow Rate (GPM)	NSF 44 Efficiency Rated (Yes/No)	CA Efficiency Rated (Yes/No)	Reduction Claims
Essential	Gold	10.0	Y	Y	Barium, Radium 226/228, Hardness
Essential	Gold HE	9.5	Y	Y	Barium, Radium 226/228, Hardness
Essential	Platinum	10.0	Y	Y	Barium, Hardness, Radium 226/228
Essential	Silver	9.0	Y	Y	Barium, Hardness, Radium 226/228
Essential	Silver HE	8.0	Y	Y	Barium, Hardness, Radium 226/228

Kinetico	2020c HE	6	Y	N	Barium, Hardness, Radium 226/228
Kinetico	2020c HF	6	Y	N	Barium, Hardness, Radium 226/228
Kinetico	2030s	9	Y	N	Barium, Hardness, Radium 226/228
Kinetico	2040s OD	11	Y	N	Barium, Hardness, Radium 226/228
Kinetico	2050s	6.4	Y	N	Barium, Hardness, Radium 226/228
Kinetico	2060s	11.5	Y	N	Barium, Hardness, Radium 226/228
Kinetico	2060s OD	20	Y	N	Barium, Hardness, Radium 226/228
Kinetico	2100s	12	Y	N	Barium, Hardness, Radium 226/228
Kinetico	2100s OD	21	Y	N	Barium, Hardness, Radium 226/228
Kinetico	2175s	13.2	Y	N	Barium, Hardness, Radium 226/228
Kinetico	4040s OD	11	Y	N	Barium, Hardness, Radium 226/228
Kinetico	Ergo 7	8.0	Y	Y	Barium, Hardness, Radium 226/228
Kinetico PremierQ850		6.0	Y	Y	Barium, Hardness, Radium 226/228
Kinetico PremierQ850 OD		11.0	Y	Y	Barium,

Hardness,  
Radium 226/228

Kinetico PremierS150		9.0	Y	Y	Barium, Hardness, Radium 226/228
Kinetico PremierS250		11.6	Y	Y	Barium, Hardness, Radium 226/228
Kinetico PremierS250 OD		20.0	Y	Y	Barium, Hardness, Radium 226/228
Kinetico PremierS350		11.2	Y	Y	Barium, Hardness, Radium 226/228
Kinetico PremierS550		16.4	Y	N	Barium, Hardness, Radium 226/228
Kinetico PremierS650		7.0	Y	Y	Barium, Hardness, Radium 226/228
Kinetico PremierS650 OD		11.0	Y	Y	Barium, Hardness, Radium 226/228
Signature	1035	10.0	Y	Y	Barium, Hardness, Radium 226/228
Signature	735	8.0	Y	Y	Barium, Hardness, Radium 226/228
Signature	935	9.0	Y	Y	Barium, Hardness, Radium 226/228

**Disclaimer:**

We are currently transferring data into the Online Certification Directory. Some of the information displayed may be out of date. While we are working through this process, please e-mail [productcertification@wqa.org](mailto:productcertification@wqa.org) (<mailto:productcertification@wqa.org>) to verify the certification status or claims of any product.

Particulate  
Class I, Taste  
and Odor

Kinetico	Kube (15410)	1.25	15421	1665	Aesthetic Chlorine, Nominal Particulate Class I, Taste and Odor
----------	--------------	------	-------	------	--

**Product Type: Point-of-Entry**

Kinetico	CRS 1100	4.0	N/A	130,000	Aesthetic Chloramine
----------	----------	-----	-----	---------	-------------------------

<sup>1</sup> The K5 Drinking Water Station is a reverse osmosis system and is also Certified under Standard NSF/ANSI 58.

**Disclaimer:**

We are currently transferring data into the Online Certification Directory. Some of the information displayed may be out of date. While we are working through this process, please e-mail [productcertification@wqa.org](mailto:productcertification@wqa.org) (<mailto:productcertification@wqa.org>) to verify the certification status or claims of any product.

# Water Quality Association

11/17/2014



## CERTIFIED DRINKING WATER TREATMENT UNITS

*NSF/ANSI 53 (04/01/2012): Drinking Water Treatment Units - Health Effects is within WQA's ANSI and SCC approved scope of accreditation under the Drinking Water Treatment Units Scheme*

### Kinetico Incorporated

10845 Kinsman Road

Newbury, OH 44065

United States

<http://www.kinetico.com> (<http://www.kinetico.com>)

### Product Type: Point-of-Use

Brand Name	Model Number	Rated Service Flow (GPM)	Replacement_	Replacement Component Service Cycle (Gallons)	Reduction Claims
Kinetico	Drinking Water Filter Model 7500	0.75	9308A	500	Lead, methyl tert-butyl ether (MTBE), VOC (as chloroform)
Kinetico	K5 Drinking Water Station <sup>1</sup>	0.75	12778	500	methyl tert-butyl ether (MTBE), VOC (as chloroform)
Kinetico	KUBE14	1.25	KUBE14F1	1665	Cyst, Lead, Mercury, methyl tert-butyl ether (MTBE), VOC (as chloroform)
Kinetico	Kube (15410)	1.25	15421	1665	Cyst, Lead, Mercury, methyl tert-butyl ether

(MTBE), VOC  
(as chloroform)

<sup>1</sup> The K5 Drinking Water Station is a reverse osmosis system and is also Certified under Standard NSF/ANSI 58.

**Disclaimer:**

We are currently transferring data into the Online Certification Directory. Some of the information displayed may be out of date. While we are working through this process, please e-mail [productcertification@wqa.org](mailto:productcertification@wqa.org) (<mailto:productcertification@wqa.org>) to verify the certification status or claims of any product.

# Water Quality Association

11/17/2014



## CERTIFIED REVERSE OSMOSIS UNITS

*NSF/ANSI 58 (06/11/2013): Reverse Osmosis Drinking Water Treatment Systems\* is within WQA's ANSI and SCC approved scope of accreditation under the Drinking Water Treatment Units Scheme*

Kinetico Incorporated

10845 Kinsman Road

Newbury, OH 44065

United States

<http://www.kinetico.com> (<http://www.kinetico.com>)

### Product Type: Systems with Storage Tank and Automatic Shut-off Valve

Brand Name	Model Number	Daily Production Rate (gpd)	Replacement Component	Reduction Claims
AquaKinetic	A-200	10.9	9306 B, 9428 A	Barium, Cadmium, Copper, Cyst, Fluoride, Hexavalent Chromium, Lead, Arsenic (V) (less than 300 ppb reduction), Radium 226/228, Selenium, TDS, Trivalent Chromium, Turbidity
Kinetico	K5 Drinking Water Station <sup>1</sup>	20.40	12752	Barium, Cadmium, Copper, Cyst, Fluoride, Hexavalent Chromium, Lead, Nitrate, Nitrite, Arsenic (V) (less



than 300 ppb  
reduction), Radium  
226/228,  
Selenium,  
Trivalent  
Chromium,  
Turbidity

Kinetico	K5 Drinking Water Station <sup>2</sup>	40.64	12752	Barium, Cadmium, Copper, Cyst, Fluoride, Hexavalent Chromium, Lead, Nitrate, Nitrite, Arsenic (V) (less than 300 ppb reduction), Radium 226/228, Selenium, TDS, Trivalent Chromium, Turbidity, VOC (as chloroform)
----------	--	-------	-------	--

<sup>1</sup> K5 Drinking Water Station with 3 gallon Standard tank - Tested and Certified for Nitrate/Nitrite reduction with part number 7329. Note: the difference between systems is tank configuration.

<sup>2</sup> K5 Drinking Water Station with 3 gallon WOW tank - Tested and Certified for Nitrate/Nitrite reduction with part number 7329. Note: the difference between systems is tank configuration.

### **Disclaimer:**

We are currently transferring data into the Online Certification Directory. Some of the information displayed may be out of date. While we are working through this process, please e-mail [productcertification@wqa.org](mailto:productcertification@wqa.org) (mailto:productcertification@wqa.org) to verify the certification status or claims of any product.

# Water Quality Association

11/17/2014



## CERTIFIED DRINKING WATER SYSTEM COMPONENTS

*NSF/ANSI-61 (03/05/2012): Drinking Water System Components - Health Effects is within WQA's ANSI and SCC approved scope of accreditation under the Drinking Water System Component Scheme*

### Kinetico Incorporated

10845 Kinsman Road  
Newbury, OH 44065  
United States

<http://www.kinetico.com> (<http://www.kinetico.com>)

### Product Type: Valve

Brand Name	Model	Water Contact Temp	Water Contact Material	Size
Kinetico	Classic 1" with AccuDial <sup>1</sup>	Cold (23C)	Various	N/A
Kinetico	Classic 1" without AccuDial <sup>1</sup>	Cold (23C)	Various	N/A
Kinetico	Hydrus Valve <sup>1</sup>	Cold (23C)	Various	N/A
Kinetico	Mach 1 1/4" By-Pass Valve <sup>1</sup>	Cold (23C)	Various	N/A
Kinetico	Mach 1 1/4" with AccuDial <sup>1,3</sup>	Cold (23C)	Various	N/A
Kinetico	Mach 1 1/4" without AccuDial <sup>1</sup>	Cold (23C)	Various	N/A
Kinetico	Slider Bypass Valve <sup>2</sup>	Cold (23C)	SYN	N/A
Kinetico	Solitaire 1" Valve <sup>2</sup>	Cold (23C)	SYN	N/A

## Product Type: Point-of-Entry

Kinetico	CP213s OD	Cold (23C)	Various	N/A
Kinetico	CP216s OD	Cold (23C)	Various	N/A
Kinetico	SRS 7x35	Cold (23C)	MLTPL	N/A
Kinetico	SRS 8x40	Cold (23C)	MLTPL	N/A

<sup>1</sup> This product is WQA Certified whether it displays the WQA Gold Seal Logo or not.

<sup>2</sup> All listed products for this company are WQA Certified, whether they display the WQA Gold Seal Logo or not.

<sup>3</sup> This valve must be used in systems with a holding volume of 3.8 gallons or more.

### Disclaimer:

We are currently transferring data into the Online Certification Directory. Some of the information displayed may be out of date. While we are working through this process, please e-mail [productcertification@wqa.org](mailto:productcertification@wqa.org) (<mailto:productcertification@wqa.org>) to verify the certification status or claims of any product.